

Standard School Name: Rye Island Elementary

Crew Leader: _____

Use additional forms if more than 10 Buildings on campus

Street Address: 5360 Ridgewood Dr.

Crew Leader Tel: _____

Crew Leader Email: _____

Inspection Date: _____

Form: _____ of _____

City, State Zip: Bolton, FL 33422

Campus Location Code: _____

Summary/Critical Observations:
Power needs to be stored to avoid mitigation of all Branding's report
Heavy tree debris throughout Per Joe Pastal no ceiling leaks report
Drawn roof inspection ~~per~~ advised no leaks observed during inspection, no water

Notes: Heavy Tree Debris throughout.

Is there Hurricane Ian related debris on site? Y or N If not, has Hurricane Ian Debris already been removed? Y or N

Notes: Heavy Tree Debris

Were there any known Hurricane Ian preparation activities? Y or N Please describe the activity and identify who performed work.

Notes: Not known.

Please identify whether there is space for temporary facilities and/or modular buildings? Please note any significant issues which might impact their use.

Notes: Work at this time due to debris

Please identify any significant issues with parking, grounds, lighting, fencing/security, and subsurface utilities

Notes: No Power or water

Pine Island Elementary

Campus Name: _____		Building FISH Number: _____	Damage Key: 0 - No damage 1 - Needs minor repairs 2 - Needs major repairs 3 - Destroyed
Building Name: <u>BLD - (2 - 12)</u> <u>SAME</u>			
	Damage (0-3)	Comments & Details	
General Site:		Heavy Tree Debris	
Building Envelope:		No Visual Damage observed or reported per Joe Postal Re-evaluate after removal of Tree Debris	
Building Interior:		No Reported Power per Joe Postal	
Mechanical:		No HVAC	
Other:		Restore Power & HVAC to avoid mitigation throughout BLD 2-12	
Category Reference: General Site - trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment; Building Envelope - Roof, windows, exterior doors, roof top equipment; Building Interior - Water intrusion, mold, debris, ceiling systems, flooring systems, interior sheet rock walls systems; Mechanical - Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.) Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.			

Campus Name: Pine Island Elementary Building FISH Number: _____ Damage Key:
 0 - No damage
 Building Name: ~~_____~~ BID 1 1 - Needs minor repairs
 2 - Needs major repairs
 3 - Destroyed

	Damage (0-3)	Comments & Details
General Site:		Honey Tree Pests
Building Envelope:		No visual damage observed, Roof Drive inspect. Possible minor roof damage. Re evaluate after removal of debris
Building Interior:		No power or water service, No observed leaks observed in Bid 1 during inspection, heavy musty smell. Power needs to be restored for HVAC to avoid mitigation throughout all BLDGS
Mechanical:		Currently No power, HVAC system Down throughout
Other:		Restore Power, Hvac System to avoid mitigation Remove Tree Debris Do not see school returning to classes in foreseeable future if power not restored to avoid mitigation

Category Reference:
 General Site – trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment;
 Building Envelope – Roof, windows, exterior doors, roof top equipment;
 Building Interior – Water intrusion, mold, debris, ceiling systems, flooring systems, interior sheet rock walls systems;
 Mechanical – Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.)
 Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.