

Campus Name: **J Colin English Elementary**

Building FISH Number: _____

Damage Key:
0 - No damage

Building Name: _____

1 - Needs minor repairs
2 - Needs major repairs
3 - Destroyed

	FSS119.071	
General Site:	1	*FSS119.071
Building Envelope:	2	The overhang connecting buildings 3 and 4 sustained damage. Most of it has been removed by the storm. Downspout and one small electrical box for the CCTV system were also damaged when the overhang was blown off. The portables located behind the building all have sustained exterior damage. Possible roof leak located above the art room in Building 2. Will need to be further investigated.
Building Interior:	1	There are 5 portable classrooms located behind the building. All 5 have suffered damage ranging from missing soffit up to walls being fully ripped open. Interiors with the exception of Portable 99-147 which has a section of wall missing exposing the interior to the elements. Building 2 "art room" Has a roof leak with visible damage to ceiling tiles, drywall, and water pooling on the floor. The flooring will need to be further investigated for water saturation as well as the cabinets adjacent to the leak location.
Mechanical:	0	All mechanicals appear to be in working order.
█	2	Recommend the portable classrooms remain closed until repaired and deemed safe. Will require structural inspection, Recommend the Art Room remain close until the flooring and cabinets are further inspected for water damage and repairs are made to the roof.

Category Reference:

Mechanical – Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.)

Standard School Name:

J Colin English Elementary

Crew Leader:

Gregg Schkade

Street Address:

Crew Leader Tel:

Use additional forms if more than 10 Buildings on campus

City, State Zip:

120 Pine Island Rd

Crew Leader Email:

Campus Location Code:

Inspection Date:

10 8 2022

Form: _____ of _____

Summary/Critical Observations:

Main builds are in good order with minor water damage from the roof in art lab. However, the portables behind the building should be closed down until a safety inspection is performed and damages are repaired.

Is the campus site accessible without special means of ingress/egress? Y or N

Notes:

All buildings were accessible. There were no obstructions to any of the egress points on all buildings.

Is there Hurricane Ian related debris on site? Y or N If not, has Hurricane Ian Debris already been removed? Y or N

Notes:

There was a significant amount of debris on site. Majority are tree branches but were in the process of being removed by cleanup crews. A few dozen sand bags are in place by the main office entry door to stop water from coming into the building. They will need to be removed as they pose a trip hazard. The 5 portable classrooms located behind the building have a large amount of debris that will need to be removed.

Were there any known Hurricane Ian preparation activities? Y or N. Please describe the activity and identify who performed work.

Notes:

There were several locations in which electronics were covered with plastic or bags. The sandbags in place by the main office door were also in place to prevent water flow into the building. Unknown as to who performed the tasks.

Please identify whether there is space for temporary facilities and/or modular buildings? Please note any significant issues which might impact their use.

Notes:

The only potential location would be the front parking lot. The areas around the building are heavily congested for a

Please identify any significant issues with parking, grounds, lighting, fencing/security, and subsurface utilities

Notes:

No issues to note. Most storm debris were actively being removed during inspection.