

Standard School Name:

Orange Wood Elementary

Crew Leader:

Street Address:

4001 DeLeon St

Crew Leader Tel:

City, State Zip:

Funkhouser, FL 33901

Crew Leader Email:

Campus Location Code:

Inspection Date:

10/12/22

Form: _____ of _____

Use additional forms if more than 10 Buildings on campus

Summary/Critical Observations:

Is the campus site accessible without special means of ingress/egress? Y or N

Notes: Some areas have limited access, designs removal in progress
Principle said they are hoping to reopen next week

Is there Hurricane Ian related debris on site? Y or N

If not, has Hurricane Ian Debris already been removed? Y or N

Notes: Debris + minor metal debris remain, removal of debris in progress

Were there any known Hurricane Ian preparation activities? Y or N. Please describe the activity and identify who performed work.

Notes: Furniture + free standing content were moved inside

Please identify whether there is space for temporary facilities and/or modular buildings? Please note any significant issues which might impact their use.

Notes: Area behind pavilion could be utilized.

Please identify any significant issues with parking, grounds, lighting, fencing/security, and subsurface utilities

Notes: DM bus removal in progress

Campus Name: <u>Overseas @L</u> Building Name: <u>(BAD) 1, 2, 3, 4, 5, 7, 8, 10, 11, 22</u> Building FISH Number: <u>SAME</u> Damage Key: 0 - No damage 1 - Needs minor repairs 2 - Needs major repairs 3 - Destroyed	Damage (0-3)	Comments & Details
General Site:		Design removal in progress
Building Envelope:		NVID
Building Interior:		NVID
Mechanical:		AC ROOMS Power on Water on
Other:		N/A

Category Reference:
 General Site - trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment;
 Building Envelope - Roof, windows, exterior doors, roof top equipment;
 Building Interior - Water intrusion, mold, debris, ceiling systems, flooring systems, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.)
 Mechanical - Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.)
 Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.

Orange Wood Elementary

Campus Name: ~~Orange Wood~~

Building FISH Number: _____

Damage Key:

0 - No damage

1 - Needs minor repairs

2 - Needs major repairs

3 - Destroyed

Building Name: BLD 6 + 12

	Damage (0-3)	BLD 12	BLD 6	Comments & Details
General Site:		Tree on w/leaves	Remove Tree from driveway	
Building Envelope:		NVD	NVD	
Building Interior:		NVD NVD	Water staining on floor - Floor Pool 6-004 - crack on back wall	6-001 evaluate crack
Mechanical:		AC running Power + Water ON	AC running Power + Water ON	
Other:		NA	NA	

Category Reference:

General Site - trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment;

Building Envelope - Roof, windows, exterior doors, roof top equipment;

Building Interior - Water intrusion, mold, debris, ceiling systems, flooring systems, interior sheet rock walls systems;

Mechanical - Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.)

Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.

07-004

Campus Name: Orangethorpe HS Building FISH Number: _____

Building Name: BLD 9011

Damage Key:
 0 - No damage
 1 - Needs minor repairs
 2 - Needs major repairs
 3 - Destroyed

	Damage (0-3)	BLD #	Comments & Details: BLD #
General Site:		Removal of debris in progress	Canopy Removal Tree and Access windows in front of Bld 11
Building Envelope:		NVD	NVD
Building Interior:		9-002 - ICT	NVD
Mechanical:		A/C running Power & Water ON	A/C Running Power & Water ON
Other:		NA	re-evaluate canopy after removal of tree leaving on canopy

Category Reference:
 General Site - trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment;
 Building Envelope - Roof, windows, exterior doors, roof top equipment;
 Building Interior - Water intrusion, mold, debris, ceiling systems, flooring systems, interior sheet rock walls systems;
 Mechanical - Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.)
 Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.

NVD BLD 1, 2, 3, 5, 6, 8, 4, 10, 11

Campus Name: OrangeWood Building FISH Number: _____ Damage Key:
 Building Name: BHDS Storage 0 - No damage
 1 - Needs minor repairs
 2 - Needs major repairs
 3 - Destroyed

	Damage (0-3)	Comments & Details :
General Site:		Minor Debris to be removed
Building Envelope:		Impact Damage Siding change Replace metal roof
Building Interior:		No Access
Mechanical:		NA
Other:		Temp repair of roof

Category Reference:
 General Site – trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment;
 Building Envelope – Roof, windows, exterior doors, roof top equipment;
 Building Interior – Water intrusion, mold, debris, ceiling systems, flooring systems, interior sheet rock walls systems;
 Mechanical – Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.)
 Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.

Campus Name: Orange wood Building FISH Number: _____

Building Name: Tennis Courts

Damage Key:
 0 - No damage
 1 - Needs minor repairs
 2 - Needs major repairs
 3 - Destroyed

	Damage (0-3)	Comments & Details :
General Site:		Damage 12' CLH/FEN + Damaged Tennis nets
Building Envelope:		NA
Building Interior:		NA
Mechanical:		NA
Other:		NA

Category Reference:
 General Site – trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment;
 Building Envelope – Roof, windows, exterior doors, roof top equipment;
 Building Interior – Water intrusion, mold, debris, ceiling systems, flooring systems, interior sheet rock walls systems;
 Mechanical – Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.)
 Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.

Campus Name: Orange Wood EL Building FISH Number: _____

Building Name: Pavilion BLD. 21

Damage Key:
 0 - No damage
 1 - Needs minor repairs
 2 - Needs major repairs
 3 - Destroyed

	Damage (0-3)	Comments & Details
General Site:		Debris removal in progress 20' x 20' Damaged canopy / covered walkway adjacent to Pavilion
Building Envelope:		Tarp & replace roof shingles & underlayment
Building Interior:		NVD
Mechanical:		NA
Other:		Tarp Roof

Category Reference:
 General Site - trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment;
 Building Envelope - Roof, windows, exterior doors, roof top equipment;
 Building Interior - Water Intrusion, mold, debris, ceiling systems, flooring systems, interior sheet rock walls systems;
 Mechanical - Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.)
 Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.

Campus Name: <u>Orangetwood EL</u>		Building FISH Number: _____	Damage Key: 0 - No damage 1 - Needs minor repairs 2 - Needs major repairs 3 - Destroyed
Building Name: <u>BLD 23</u>			
	Damage (0-3)	Comments & Details	XXXXXXXXXX
General Site:		Debris removal in progress	
Building Envelope:		NVP	
Building Interior:		23-022. water stain by window 23-004 ET 2.	
Mechanical:		AC Running Power ON Water ON	
Other:		No issues	
<p>Category Reference: General Site - trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment; Building Envelope - Roof, windows, exterior doors, roof top equipment; Building Interior - Water intrusion, mold, debris, ceiling systems, flooring systems, interior sheet rock walls systems; Mechanical - Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.) Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.</p>			

Martina Bryan Ferguson

o Jamie Bowler

Campus Name: <u>Orangethorpe BL</u>		Building FISH Number: _____	Damage Key: 0 - No damage 1 - Needs minor repairs 2 - Needs major repairs 3 - Destroyed
Building Name: <u>BTW 12-22</u> <u>CANOPY/WALKWAY</u>			
	Damage (0-3)	Comments & Details :	
General Site:		Removal of debris in progress	
Building Envelope:		Covered walkway 652F Roof	
Building Interior:		NA	
Mechanical:		NA	
Other:		Safe off any loose metal	
Category Reference: General Site - trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment; Building Envelope - Roof, windows, exterior doors, roof top equipment; Building Interior - Water intrusion, mold, debris, ceiling systems, flooring systems, interior sheet rock walls systems; Mechanical - Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.) Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.			