

FEDERAL EMERGENCY MANAGEMENT AGENCY  
**PRELIMINARY DAMAGE ASSESSMENT SITE ESTIMATE**

DATE  
 10-7-22

**PART I — APPLICANT INFORMATION**

COUNTY	NAME OF APPLICANT	NAME OF LOCAL CONTACT	PHONE NO.
--------	-------------------	-----------------------	-----------

**PART II — SITE INFORMATION**

KEY FOR DAMAGE CATEGORY (Use appropriate letters in the "category" blocks below)

- |                        |                             |   |
|------------------------|-----------------------------|---|
| a. DEBRIS REMOVAL      | d. WATER CONTROL FACILITIES | g. OTHER (Parks, Recreational Facilities, etc.) |
| b. PROTECTIVE MEASURES | e. PUBLIC BUILDINGS         |   |
| c. ROADS AND BRIDGES   | f. PUBLIC UTILITIES         |   |

SITE NO.	CATE-GORY	LOCATION (Use map location, address, etc.)
		South A. Myers H.S. 3511 (SFMHS)

DESCRIPTION OF DAMAGE  
 Roof Patches displaced throughout ALL ROOF ELEVATIONS.  
 NOTE: Patches were warranty repair for "Blisters"

IMPACT:	% COMPLETE	COST ESTIMATE

SITE NO.	CATE-GORY	LOCATION (Use map location, address, etc.)

DESCRIPTION OF DAMAGE  
 Roof membrane "Blistered" throughout ALL ROOF ELEVATIONS.

IMPACT:	% COMPLETE	COST ESTIMATE

SITE NO.	CATE-GORY	LOCATION (Use map location, address, etc.)

DESCRIPTION OF DAMAGE  
 Kitchen Exhaust Fan missing Cover

IMPACT:	% COMPLETE	COST ESTIMATE

SITE NO.	CATE-GORY	LOCATION (Use map location, address, etc.)

DESCRIPTION OF DAMAGE

IMPACT:	% COMPLETE	COST ESTIMATE

NAME OF INSPECTOR James Swallock	AGENCY	OFFICE PHONE NO.	HOME PHONE NO.
-------------------------------------	--------	------------------	----------------