

Standard School Name: Cape Coral HS

Crew Leader: Ed Schlager / Matt Gil

Street Address: 2300 Santa Barbara Blvd

Crew Leader Tel: \_\_\_\_\_

Use additional forms if more than 10 Buildings on campus

City, State Zip: Cape Coral

Crew Leader Email: \_\_\_\_\_

Campus Location Code: \_\_\_\_\_

Inspection Date: 10/6/22

Form: \_\_\_\_\_ of \_\_\_\_\_

Summary/Critical Observations:  
Roof metal edge blown up around the building, granular surface stripped off. 5 rooms in one block have significant water intrusion + require mitigation. Debris not cleaned up. No power but should be restored today.  
(3) classrooms will be off line if school opens soon.

Is the campus site accessible without special means of ingress/egress?  Y or N

Notes:

Is there Hurricane Ian related debris on site?  Y or N If not, has Hurricane Ian Debris already been removed? Y or N

Notes:

Were there any known Hurricane Ian preparation activities? Y or N. Please describe the activity and identify who performed work.

Notes: —

Please identify whether there is space for temporary facilities and/or modular buildings? Please note any significant issues which might impact their use.

Notes: large fields

Please identify any significant issues with parking, grounds, lighting, fencing/security, and subsurface utilities

Notes: —

10/6/22

Campus Name: Cape Coral HS Building FISH Number: \_\_\_\_\_ Damage Key:  
 0 - No damage  
 1 - Needs minor repairs  
 2 - Needs major repairs  
 3 - Destroyed

Building Name: \_\_\_\_\_

	Damage (0-3)	Comments & Details
General Site:	2	Requires new roof. extensive damage to fields. a few rooms with heavy water damage. Hurricane windows installed last year are 100% damage
Building Envelope:	2	needs roof replacement
Building Interior:	1-2	Generally minor repairs, with a few class rooms needing significant repair. VTC floors rising in stairwells & cafeteria. water mitigation needed 11-184, 11-182, 01-275, 01-262, halls outside class rooms & 1st floor Room 11-170 strong odor & fear of fire
Mechanical:		No power. unknown if HVAC is damaged water is on
Other:		Major repairs to fields, field house, score board, fencing et, Grounds are mostly cleaned up

**Category Reference:**

General Site – trees, light poles, signage, bleachers, concession buildings, out buildings, scoreboards, canopies, and playground equipment;

Building Envelope – Roof, windows, exterior doors, roof top equipment;

Building Interior – Water intrusion, mold, debris, ceiling systems, flooring systems, interior sheet rock walls systems;

Mechanical – Exterior transformer, water/fire main valves, interior switch gear, interior electrical distribution panels, chiller plants and associated equipment (chillers, pumps cooling towers, etc.)

Other - Specific emergency repairs required to render each building safe, sanitary and secure for students and staff to resume school operations.