



THE SCHOOL DISTRICT OF LEE COUNTY

PROCUREMENT SERVICES

DEPARTMENT

Richard Cowie, Procurement Agent

ADDENDUM TO CONTRACT DOCUMENTS

ADDENDUM NO.: 1

PROJECT NAME: ITN No. N187338RC – Flooring and Related Services

DATE OF ISSUE: September 17, 2018

The following information shall be included in the ITN documents and is hereby made part of the project bid documents in the form of clarification, addition, deletion or revision to the contract specifications.

Proposer's questions/issues and District answers:

- Q1. Items 1,2,3,5,6,7,8,9,10,12,13,14,15,16, & 17 in attachment A are not items listed in the specifications, most items are discontinued that are listed in attachment A. Items in specifications need to be listed in attachment A.
- A1. *The District has revised and released Attachment A (Revision 1).*
- Q2. Items 20- 24 in attachment A do not need separate line items, material is priced by the linear foot no matter the size.
- A2. *The District has revised and released Attachment A (Revision 1).*
- Q3. Item 33 in attachment A needs to be more detailed, need separate pricing lines for ceramic wall tile & 2"x2" mosaics floor tile. Specifications call for 6"x6" Colours Schemes floor tile which is a discontinued product, previous schools installed by Acousti all used 2"x2" or 1"xl" mosaic floor tile.
- A3. *The District has revised and released Attachment A (Revision 1).*
- Q4. Specifications 093000 "Tiling" call for Strataflex waterproofing membrane & Schluter Ditra for crack isolation, the two systems are not compatible or cost effective for school applications. We recommend using Proflex Hydraseal for both waterproofing and crack isolation.
- A4. *The District has revised Appendix H Tiling, Specifications 093000, Section 2.4.B.b to include Proflex Hydraseal.*
- Q5. Item 43 in attachment A need two separate line items, one for demolition of wall tile and one for demolition of floor tile.
- A5. *The District has revised and released Attachment A (Revision 1).*

- Q6. Item 47 in attachment A is not listed in specifications and products listed in specifications need to be listed in attachment A.
- A6. *The District has revised Appendix F Moisture Emission Control, Section 03 54 19, Part 2, 2.01 and 2.02 to include Ardex products.*
- Q7. In attachment A by the stair treads there needs to be a line item for stringers.
- A7. *The District has revised and released Attachment A (Revision 1).*
- Q8. Item 27 in Attachment A needs two separate line items, one for 4 coats of wax and one for 6 coats of wax.
- A8. *The District has revised and released Attachment A (Revision 1).*
- Q9. In detailed specifications item #5 payables are through the Master card network, what are the fees associated with this program? If there are fees who is responsible for these fees?
- A9. *Proposers should contact their preferred financial institution to find out what the fees are. The awarded vendor or vendors will be responsible for fees charged by their financial institution. Proposers should take this into consideration when submitting prices on Attachment A (Revision 1). See instructions for Attachment A in the Detailed Specifications, Section 11, j., third sentence on page 15.*
- “Pricing shall be all inclusive. For example, pricing shall include all required insurance, licenses, and bonds; overhead; profit; vehicles; and labor per hour and supervision.”*

There are no other changes at this time. Please acknowledge this addendum via Attachment D, Addenda Acknowledgement Form.

Thank you for your interest in the School District of Lee County.


Richard Cowie
Procurement Agent