



# PROCUREMENT SERVICES

## ADDENDUM TO CONTRACT DOCUMENTS

ADDENDUM NO.: 3

PROJECT NAME: ITN No. N247486MG – **Flooring and Related Services**

DATE OF ISSUE: August 6, 2024

---

The following information shall be included in the ITN documents and is hereby made part of the contract documents in the form of clarification, addition, deletion or revision to the instruction to the respondent and specifications.

---

The following dates have been extended:

<b>ITN Due in Bonfire:</b>	<b>August 20, 2024</b>
<b>Evaluation Review and Scoring Meeting:</b>	<b>August 27, 2024</b>
<b>Interviews (Optional):</b>	<b>September 3, 2024</b>

Q1. On the Item No 1-49. There are several items 1-13 that say District Approved. Can I obtain the list of District approved items?

*A1. Carpet Squares (Mohawk, Shaw & Milliken) LVT (Mohawk, Shaw & Tarkett).  
The District will require a price submitted for each manufacturer in lieu of manufacturer-specific product lines, product lines tend to discontinue or some points do not have the readily available stock on hand for projects that may require prioritization. Pricing should be submitted to cover a broad selection of carpet tiles with color accents and LVT styles to include Stone/Wood looks with accent colors if approved. Each of these will have a line on the Proposal Response Form as provided for submittal.*

Q2. Comparing the last bid to the current one, the last bid has almost a tier level, as in a low medium-high level of material and the current has a vendor and that's it, almost as if there is one carpet selection per vendor. Is that correct?

*A2. Document 02. Proposal Response Form has been revised. A copy of this form has been uploaded into Bonfire named 09. Revised Proposal Response Form.*

Q3. I contacted each flooring vendor listed on this ITN and they all agree we need minimal specifications to bid properly, they all have more than one product to meet the below specifications. Please include the below specifications as a requirement for this ITN. Mohawk carpet tie- Construction- Tufted, Fiber- Duracolor, Dye- Solution Dyed, Backing- Ecoflex One, Pile Weight- 17oz, Gauge- 1 1/12", Stitches per inch- 12.4, Density- 6800, TARR rating- Severe, Warranty- Lifetime Shaw- Construction- Multi-Level Pattern Loop, Fiber- Ecosolution Nylon, Dye- Solution Dyed, Backing- Ecologix One, Pile Weight- 16oz Gauge- 1/12", Density- 5434, TARR Rating- Severe, Warranty- Lifetime Milliken- Construction- Multi-Level Pattern Loop, Fiber- 100% Nylon type 6 or 6,6, Dye- Solution Dyed, Backing- PVC free Polyurethane Cushion, Pile Weight- 14oz, gauge- 11/12", Stitches per inch- 8.5, Density- 5500, TARR Rating- Severe or Heavy, Warranty- Lifetime. LVT Mohawk- Thickness- 2.5mm, Wear Layer- 20 mil, Finish- M-Force Ultra, Edge Profile- Mikro Beveled, Product type- Glue down LVT, Warranty- 20 year Shaw- Thickness-2.5mm, Wear Layer- 20 mil, Finish- Exogaurd +, Edge Profile- Square, Product type- Glue down LVT, Warranty- 15 year Tarkett- Thickness- 3mm, Wear Layer- 20mil, Finish- Techtone, Edge Profile- Square, Product type- Glue Down LVT, Warranty- 25year



## PROCUREMENT SERVICES

A3. We have included the following Exhibits:

- 10. Exhibit 5 – Shaw Product Specifications
- 11. Exhibit 6 – Mohawk Product Specifications
- 12. Exhibit 7 – Tarkett Product Specifications
- 13. Exhibit 8 – Milliken Product Specifications

If you would like to view the previous meeting that was held on July 10, 2024, please click on the link below:

[https://leeschoolsfl-my.sharepoint.com/:v/g/personal/melissarg\\_leeschools\\_net/Eawh\\_ZV0wN1Pqo2I4LSFi6IBUQ3escKAKThqkmTcY5xeFg?e=prdxuH](https://leeschoolsfl-my.sharepoint.com/:v/g/personal/melissarg_leeschools_net/Eawh_ZV0wN1Pqo2I4LSFi6IBUQ3escKAKThqkmTcY5xeFg?e=prdxuH)

There are no other changes at this time. Please acknowledge this addendum via Attachment B. Addenda Acknowledgement Form.

***Thank you for your interest in The School Board of Lee County.***

Sincerely,

Melissa Gross  
Procurement Agent